

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-0028:213 Page 1 of 1

CATEGORY: Power Units

LISTEE: Notifier, One Fire-Lite Place, Northford, CT 06472-1653
Contact: Lawrence Flood (203) 484-1200

DESIGN: Model ACPS-2406 Auxiliary addressable power supply and battery charger. Can be configured to drive four notification appliance circuits or, it may be configured to provide four-wire detector power or general purpose power. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120/240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, electrical rating and UL label.

APPROVAL: Listed as auxiliary power supply for use with separately listed electrically and functionally compatible fire alarm control units.

10-11-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager